



**GBI ASSESSMENT CRITERIA
INDUSTRIAL NEW CONSTRUCTION (INC)**

VERSION 1.0 | JUNE 2011

www.greenbuildingindex.org | info@greenbuildingindex.org

GREENBUILDINGINDEX SDN BHD (845666-V) 4 & 6 Jalan Tangsi, 50480 Kuala Lumpur, Malaysia Tel 603 2694 4182 Fax 603 2697 4182

CONTENTS

PAGE	2	ACKNOWLEDGEMENT & COPYRIGHT
		INTRODUCTION
PAGE	3	What is the Green Building Index (GBI)?
PAGE	3	Who can use the GBI Industrial New Construction (INC) Tool?
PAGE	3	How to use the GBI Industrial New Construction (INC) Tool?
PAGE	4	PROJECT INFORMATION
		ASSESSMENT CRITERIA
PAGE	5	Summary of Final Score
PAGE	6	Summary of Contents
		INDIVIDUAL ITEM SCORE
PAGE	8	PART 1: Energy Efficiency (EE)
PAGE	10	PART 2: Indoor Environmental Quality (EQ)
PAGE	13	PART 3: Sustainable Site Planning & Management (SM)
PAGE	16	PART 4: Materials & Resources (MR)
PAGE	17	PART 5: Water Efficiency (WE)
PAGE	18	PART 6: Innovation (IN)

ACKNOWLEDGEMENT & COPYRIGHT

The Green Building Index has been developed by PAM and ACEM for the purposes as mentioned above and may be subject to further updating and/or modification in future.

The Green Building Index (GBI) is based upon the existing rating tools such as the Singapore Green Mark and the Australian Green Star system, amongst others which have been extensively modified for the Malaysian application. Grateful acknowledgment is made to the owners of copyright for these systems for use of their documents, information and materials in the development of the GBI.

While every care has been taken by PAM and ACEM in the development of the GBI to establish and acknowledge copyright of the information and materials used, and contact the copyright owners known to PAM/ACEM, PAM and ACEM tender their apologies for any accidental copyright infringement.

The GBI is a copyright of PAM and ACEM in which PAM and ACEM reserve all rights. No part of the GBI may be used, modified, reproduced, stored in a retrieval system or transmitted in any form, or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written permission of PAM and ACEM.

DISCLAIMERS

PAM and ACEM shall not be held liable for any improper or incorrect use of the GBI (inclusive of the materials and/or information contained therein) and assume no responsibility for any user's use of it. In no event shall PAM and ACEM be liable for any damages whatsoever, whether direct, indirect, incidental, special, exemplary or consequential (including, but not limited to business interruption or loss of use, data or profits) regardless of cause, and on any basis of liability, whether in contract, strict liability or tort (including negligence, misrepresentation or otherwise) arising in any way out of the use of the GBI or the information and materials contained therein.

The information and materials in the GBI are provided "as is" and without warranties of any kind expressed or implied. PAM and ACEM do not warrant or make representations as to the accuracy and completeness of any information and/or materials contained therein. While every effort has been made to check the accuracy and completeness of the information and materials given, the users should always make their own relevant checks. Accordingly, PAM and ACEM do not accept responsibility and liability for misstatements made in it or misunderstanding from it.

The GBI is no substitute for professional advice. Users are advised to consult with appropriate and accredited professional advisors for advice concerning specific matters pertaining to the GBI before adopting or using it. PAM and ACEM disclaim any responsibility for positions taken by users in their individual cases or for any misunderstandings and losses, direct or indirectly, on the part of the users.

PAM and ACEM do not endorse or otherwise acknowledge the GBI rating achieved by the use of the GBI. PAM and ACEM offer a formal certification process for ratings; which service provides for independent third party review of points claimed to ensure that all credits can be demonstrated to be achieved by the provision of the necessary documentary evidence. Use of the GBI without formal certification by PAM and ACEM does not entitle the user or any other party to promote the achieved GBI rating. Notwithstanding the above, neither the GBI formalization nor any certification issued by PAM and ACEM shall be used for advertising or product/services endorsement purposes.

INDEMNIFICATION

To the extent permitted by applicable law, by using the GBI, the user agrees to defend, indemnify, and hold harmless, PAM and ACEM, their officers, employees, members, representatives and agents from and against all claims and expenses of whatsoever kind and amount, arising out of the user's use of the GBI or materials and information contained therein and not to pursue any cause of action whatsoever against PAM and ACEM under any conceivable circumstances.

INTRODUCTION

WHAT IS THE GREEN BUILDING INDEX (GBI)?

The Green Building Index is an environmental rating system for buildings developed by PAM (Pertubuhan Arkitek Malaysia / Malaysian Institute of Architects) and ACEM (the Association of Consulting Engineers Malaysia). The Green Building Index is Malaysia's first comprehensive rating system for evaluating the environmental design and performance of Malaysian buildings based on the six (6) main criterias of Energy Efficiency, Indoor Environment Quality, Sustainable Site Planning & Management, Materials & Resources, Water Efficiency, and Innovation.

The Green Building Index is fundamentally derived from existing rating tools, including the Singapore Green Mark and the Australian Green Star system, but extensively modified for relevance to the Malaysian tropical weather, environmental context, cultural and social needs.

This PAM/ACEM GBI initiative aims to assist the building industry in its march towards sustainable development. The GBI environmental rating system is created to:

- **Define green building by establishing a common language and standard of measurement;**
- **Promote integrated, whole-building design;**
- **Recognise and reward environmental leadership;**
- **Transform the built environment to reduce the environmental impact of development; and**
- **Ensure new buildings remain relevant in the future and existing buildings are refurbished properly to remain relevant.**

WHO CAN USE THE GBI INDUSTRIAL NEW CONSTRUCTION (INC) TOOL?

PAM/ACEM encourage all members of Project Teams, Building owners, Developers and other interested parties (including Contractors, Government and Design and Build Contractors) to use the Green Building Index to validate environmental initiatives of the design phase of new industrial construction or base industrial building refurbishment; or construction and procurement phase of industrial buildings and their industrial process. Use of the Green Building Index is encouraged on all such projects to assess and improve their environmental attributes.

Use of the Green Building Index Industrial New Construction (INC) Tool without formal certification by an independent accredited GBI Certifier does not entitle the user or any other party to promote the Green Building Index rating achieved. No fee is payable to PAM/ACEM for such use, however formal recognition of the Green Building Index rating - and the right to promote same - requires undertaking the formal certification process offered by PAM/ACEM.

All Green Building Index rating tools are reviewed annually; please forward any feedback to info@greenbuildingindex.org

HOW TO USE THE GBI INDUSTRIAL NEW CONSTRUCTION (INC) TOOL?

- Complete the Building Input worksheet as the building's type and location may affect the predicted rating.
- Complete the remaining worksheets by reviewing each credit in each category and entering the number of points you predict the building will achieve in the 'No. of Points Achieved' column. Calculators are provided for a number of the tool's credits.
- Enter any points that may be achieved but need to be confirmed in the 'Points to be Confirmed' column.
- Enter any comments required in the 'Comments' column.
- The predicted rating is shown in the Summary worksheet. More detail on point scores (both achieved and those to be confirmed) are shown in the Credit Summary and Graphical Summary worksheets at the end of the tool.

PROJECT INFORMATION

NAME OF BUILDING	
ADDRESS OF BUILDING	
POSTCODE	
STATE	

APPLICANT	
CONTACT PERSON	

ARCHITECT	
CIVIL ENGINEER	
STRUCTURAL ENGINEER	
MECHANICAL ENGINEER	
ELECTRICAL ENGINEER	
QUANTITY SURVEYOR	
LAND SURVEYOR	
LANDSCAPE CONSULTANT	
OTHER SPECIALIST CONSULTANT(S)	
MAIN CONTRACTOR	
LOCAL AUTHORITY	
TOTAL GROSS FLOOR AREA	
LAND AREA FOR LANDED PROPERTY	

BUILDING AND INDUSTRIAL PROCESS DESCRIPTION	

DETAIL ASSESSMENT CRITERIA SUMMARY OF FINAL SCORE

PART	ITEM	MAXIMUM POINTS	SCORE
1	Energy Efficiency	33	
2	Indoor Environmental Quality	22	
3	Sustainable Site Planning & Management	18	
4	Material & Resources	10	
5	Water Efficiency	10	
6	Innovation	7	
TOTAL SCORE		100	

GREEN BUILDING INDEX CLASSIFICATION

POINTS	GBI RATING
86 to 100 points	Platinum
76 to 85 points	Gold
66 to 75 points	Silver
50 to 65 points	Certified

DETAIL ASSESSMENT CRITERIA SUMMARY OF CONTENTS

PART	CRITERIA	ITEM	POINTS	TOTAL	
1	EE	ENERGY EFFICIENCY		33	
	Design & Performance				
	EE1	Minimum EE Performance	1		
	EE2	Lighting Zoning	3		
	EE3	Electrical Sub-metering	1		
	EE4	Renewable Energy & Onsite Energy Capture/Recovery	8		
	EE5	Advanced or Improved EE Performance - BEI and/or EUI	10		
	Commissioning				
	EE6	Enhanced Commissioning	4		
	EE7	On-going Post Occupancy Commissioning	2		
	Verification & Maintainence				
EE8	EE Verification	2			
EE9	Sustainable Maintenance	2			
2	EQ	INDOOR ENVIRONMENTAL QUALITY		22	
	Air Quality				
	EQ1	Minimum IAQ Performance	1		
	EQ2	Environmental Tobacco Smoke (ETS) Control	1		
	EQ3	Carbon Dioxide Monitoring and Control	1		
	EQ4	Indoor Air Pollutant & Industrial Chemical Exposure	3		
	EQ5	Mould Prevention	1		
	Occupant Comfort				
	EQ6	Thermal Comfort: Design & Controllability of Systems	2		
	EQ7	Air Change Effectiveness	1		
	EQ8	Breakout Spaces	1		
	Lighting, Visual & Acoustic Comfort				
	EQ9	Daylighting	2		
	EQ10	Daylight Glare Control	1		
	EQ11	Electric Lighting Levels	1		
	EQ12	High Frequency Ballasts	1		
EQ13	External Views	2			
EQ14	Internal Noise Levels	1			
Verification					
EQ15	IAQ Before & During Occupancy	2			
EQ16	Post Occupancy Comfort Survey: Verification	1			

DETAIL ASSESSMENT CRITERIA SUMMARY OF CONTENTS (CONTINUED)

PART	CRITERIA	ITEM	POINTS	TOTAL
3	SM	SUSTAINABLE SITE PLANNING & MANAGEMENT		18
	Site Planning			
	SM1	Site Selection	1	
	SM2	Brownfield Redevelopment	1	
	SM3	Development Density & Community Connectivity	2	
	SM4	Environment Management	2	
	SM5	Noise Pollution	1	
	Construction Management			
	SM6	Earthworks - Construction Activity Pollution Control	1	
	SM7	QLASSIC	1	
	SM8	Workers' Site Amenities	1	
	Transportation			
	SM9	Public Transportation Access & Transportation Plan	1	
	SM10	Green Vehicle Priority	1	
	SM11	Parking Capacity	1	
SM12	Cargo Delivery Route and Proximity	1		
Design				
SM13	Stormwater Design – Quality & Quantity	1		
SM14	Greenery & Roof	2		
SM15	Building User Manual	1		
4	MR	MATERIALS & RESOURCES		10
	Reused & Recycled Materials			
	MR1	Materials Reuse and Selection	2	
	MR2	Recycled Content Materials	2	
	Sustainable Resources			
	MR3	Regional Materials	1	
	MR4	Sustainable Timber	1	
	Waste Management			
	MR5	Storage & Collection of Recyclables	1	
MR6	Construction Waste Management	2		
Green Products				
MR7	Refrigerants & Clean Agents	1		
5	WE	WATER EFFICIENCY		10
	Water Harvesting & Recycling			
	WE1	Rainwater Harvesting	2	
	WE2	Water Recycling	2	
	Increased Efficiency			
	WE3	Water Efficient - Irrigation/Landscaping	2	
WE4	Water Reduction	2		
WE5	Metering & Leak Detection System	2		
6	IN	INNOVATION		7
	IN1	Innovation & Environmental Design Initiatives	6	
	IN2	Green Building Index Facilitator	1	
			TOTAL POINTS	100

1

ENERGY EFFICIENCY (EE)

DESIGN & PERFORMANCE | COMMISSIONING | VERIFICATION & MAINTENANCE

33 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
DESIGN & PERFORMANCE				
EE1	MINIMUM EE PERFORMANCE			
	Building envelope to achieve minimum energy efficiency (EE) performance so as to reduce energy consumption, thereby reducing CO ₂ emission to the atmosphere. To meet the following minimum EE requirements as stipulated in MS 1525:		1	
	a. Submit calculations for OTTV ≤ 50 and RTTV ≤ 25 (use of BEIT software or other GBI approved softwares is permitted) AND	1		
	b. Install Energy Management Control system where Air-conditioned space ≥ 4000 m ²			
EE2	LIGHTING ZONING			
	Provide flexible lighting controls to optimise energy savings:		3	
	All individual or enclosed spaces to be individually switched; and the size of individually switched lighting zones shall not exceed 100m ² for 90% of the NLA (building and industrial plant area); with switching clearly labelled and easily accessible by occupants.	1		
	Provide auto-sensor controlled lighting in conjunction with daylighting strategy for all perimeter zones and daylight areas and/or provide task lighting for at least 25% (separate from motion sensor provision) of industrial plant area.	1		
	Provide motion sensors or equivalent to complement lighting zoning for at least 25% NLA of building OR provide task lighting for at least 25% (separate from auto-sensor provision) of industrial plant area.	1		
EE3	ELECTRICAL SUB-METERING			
	Monitor energy consumption of key building services, tenancy and industrial plant areas: Provide sub-metering for all energy uses ≥ 100kVa; with separate sub-metering for lighting and separately for power, and for industrial processes.	1	1	
EE4	RENEWABLE ENERGY & ONSITE ENERGY CAPTURE/RECOVERY			
	Encourage use of renewable energy and/or onsite energy capture/recovery.		8	
	Where 0.5% or 5 kWp whichever is the greater, of the equivalent total electricity consumption is generated by renewable energy and/or onsite energy capture/recovery, OR	1		
	Where 1.0% or 10 kWp whichever is the greater, of the equivalent total electricity consumption is generated by renewable energy and/or onsite energy capture/recovery, OR	2		
	Where 1.5% or 20 kWp whichever is the greater, of the equivalent total electricity consumption is generated by renewable energy and/or onsite energy capture/recovery, OR	4		
	Where 2.0% or 40 kWp whichever is the greater, of the equivalent total electricity consumption is generated by renewable energy and/or onsite energy capture/recovery, OR	6		
	Where 2.5% or 60 kWp whichever is the greater, of the equivalent total electricity consumption is generated by renewable energy and/or onsite energy capture/recovery.	8		
EE5	ADVANCED OR IMPROVED EE PERFORMANCE - BEI AND/OR EUI			
	Exceed Energy Efficiency (EE) performance better than the baseline minimum to reduce energy consumption in the building and/or the industrial plant process. For the building, improve Building Energy Intensity (BEI) as defined by GBI (use of GBI approved software is permitted). For industrial plant process, use Energy Use Intensity (EUI) to compare against baseline data for similar plant process (baseline EUI shall be furnished by applicant for GBI acceptance). Use BEI or EUI if either building or industrial plant process energy use constitutes more than 75% of the total energy use. Otherwise, calculate both BEI and EUI with the lower point score applicable.		10	
	BEI ≤ 180 or EUI improvement ≥ 10%	1		
	BEI ≤ 150 or EUI improvement ≥ 25%	3		
	BEI ≤ 140 or EUI improvement ≥ 30%	4		
	BEI ≤ 130 or EUI improvement ≥ 35%	5		
	BEI ≤ 120 or EUI improvement ≥ 40%	6		
	BEI ≤ 110 or EUI improvement ≥ 45%	7		
	BEI ≤ 100 or EUI improvement ≥ 50%	8		
	BEI ≤ 90 or EUI improvement ≥ 55%	10		

Continued on next page >>

GREEN BUILDING INDEX ASSESSMENT CRITERIA FOR INDUSTRIAL NEW CONSTRUCTION (INC)

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
COMMISSIONING				
EE6	ENHANCED COMMISSIONING			
	<p>Ensure the energy related systems of the building and industrial process are properly commissioned so as to realise their full potential. Appoint a GBI recognised Commissioning Specialist (CxS) to perform the commissioning for all the facility's energy related systems in accordance with ASHRAE Commissioning Guideline or other GBI approved equivalent standard by:</p> <ol style="list-style-type: none"> 1. Conducting at least one commissioning design review during the detail design stage and back-check the review comments during the tender documentation stage. 2. Developing and incorporating commissioning requirements into the tender documents. 3. Developing and implementing a commissioning plan. 4. Verifying the installation and performance of the systems to be commissioned. 5. Reviewing contractor submittals applicable to systems being commissioned for compliance. 6. Developing a systems manual that provides future operating staff the information needed to understand and optimally operate the commissioned systems. 7. Verifying that the requirements for training operating personnel, building occupants and industrial plant workers are completed. 	4	4	
EE7	ON-GOING POST OCCUPANCY COMMISSIONING			
	<p>Carry out post occupancy/post process operation commissioning for all tenancy and industrial areas after fit-out/plant modification changes are completed:</p>			
	<p>1) Design engineer shall review all fit-out plans/plant modifications to ensure original design intent is not compromised and upon completion of the fit-out/plant modification works, verify and fine-tune the installations to suit.</p>	1	2	
	<p>2) Within 12 months of practical completion (or earlier if there is at least 50% occupancy/ plant operation), the CxS shall carry out a full post/re-commissioning of the energy related systems to verify that their performance is sustained in conjunction with the completed fit-outs/modifications.</p>	1		
VERIFICATION & MAINTENANCE				
EE8	EE VERIFICATION			
	<p>Verify predicted energy use of key building services and industrial plant process:</p>			
	<p>1) Use Energy Management System to monitor and analyse energy consumption including reading of sub-meters, AND</p> <p>2) Fully commission EMS including Maximum Demand Limiting programme within 12 months of practical completion (or earlier if there is at least 50% building occupancy or plant operation).</p>	2	2	
EE9	SUSTAINABLE MAINTENANCE			
	<p>Ensure the energy related systems will continue to perform as intended beyond the 12 months Defects & Liability Period:</p>			
	<p>1) At least 50% of permanent maintenance team to be on-board one (1) to three (3) months before practical completion and to fully participate (to be specified in contract conditions) in the Testing & Commissioning of all energy services, AND</p> <p>2) Set up a permanent Energy Monitoring Committee (EMC) to ensure that plant energy performance is continuously monitored and improved.</p>	1	2	
	<p>3) Provide for a designated facility maintenance office that is fully equipped with facilities (including tools and instrumentation) and inventory storage, AND</p> <p>4) Provide evidence of documented plan for at least 3-year facility maintenance and preventive maintenance budget (inclusive of staffing and outsourced contracts).</p>	1		
ENERGY EFFICIENCY (EE) TOTAL			33	

2

INDOOR ENVIRONMENTAL QUALITY (EQ)

AIR QUALITY | OCCUPANT COMFORT | LIGHTING, VISUAL & ACOUSTIC COMFORT | VERIFICATION

22 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
AIR QUALITY				
EQ1	MINIMUM IAQ PERFORMANCE			
	<p>Establish minimum indoor air quality (IAQ) performance to enhance indoor air quality in building (and industrial plant area where applicable), thus contributing to the comfort and well-being of the occupants:</p> <p>Meet the minimum requirements of ventilation rate in ASHRAE 62.1 or the local building code whichever is the more stringent.</p>	1	1	
EQ2	ENVIRONMENTAL TOBACCO SMOKE (ETS) CONTROL			
	<p>Meet the minimum requirements of ventilation rate in ASHRAE 62.1 or the local building code whichever is the more stringent; OR</p> <p>Prohibit smoking in the building and industrial plant area except in designated smoking rooms and establish negative pressure in the smoking rooms together with provision of effective air filtration system.</p>	1	1	
EQ3	CARBON DIOXIDE MONITORING AND CONTROL			
	<p>Provide response monitoring of carbon dioxide levels to ensure delivery of optimal outside air requirements:</p> <p>Install carbon dioxide (CO₂) monitoring and control system with at least one (1) CO₂ sensor at all main return air points on each air-conditioned floor/zone to facilitate continuous monitoring and adjustment of outside air ventilation rates to each floor/zone, and ensure independent control of ventilation rates to maintain CO₂ level ≤ 1,000ppm</p>	1	1	
EQ4	INDOOR AIR POLLUTANT & INDUSTRIAL CHEMICAL EXPOSURE			
	<p>Reduce detrimental impact on occupant/worker's health from finishes that emit internal air pollutants and exposure to industrial chemicals:</p>			
	<p>1) Use low VOC paint and coating throughout the building. Paints and Coatings to comply with requirements specified in international labelling schemes recognized by GBI, AND</p> <p>2) Use low VOC carpet or flooring throughout the building. Carpets to comply with requirements specified in international labelling schemes recognized by GBI. Other types of flooring to comply with requirements under FloorScore developed by Science Certification System or equivalent, AND</p> <p>3) Use low VOC adhesive and sealant or no adhesive or sealant used.</p>	1	3	
	<p>Use products with no added urea formaldehyde. These include:</p> <p>1) Composite wood and agrifiber products defined as: particleboard, medium density fiberboard (MDF), plywood, wheatboard, strawboard, panel substrates and door cores, AND</p> <p>2) Laminating adhesives used to fabricate on-site and shop-applied composite wood and agrifiber assemblies, AND</p> <p>3) Insulation foam, AND</p> <p>4) Draperies.</p>	1		
	<p>Minimise air pollutants of industrial plant process by using environmental friendly house keeping chemicals and minimise microbial contamination and NOX emission.</p>	1		
EQ5	MOULD PREVENTION			
	<p>Design system(s) which reduce the risk of mould growth and its associated detrimental impact on occupant health:</p> <p>Demonstrate that the mechanical air-conditioned ventilation system will maintain a positive indoor air pressure relative to the exterior and can actively control indoor air humidity to be no more than 70% RH without the use of active control that will consume additional energy.</p> <p>Ensure that excessive moisture in building is controlled during the Design, Construction and Operation stages by the consideration and the control of the following:</p> <p>1) Rainwater leakage through roof and walls</p> <p>2) Infiltration of moist air</p> <p>3) Diffusion of moisture through walls, roof and floors</p> <p>4) Groundwater intrusion into basements and crawl spaces through walls and floors</p> <p>5) Leaking or burst pipes</p> <p>6) Indoor moisture sources</p> <p>7) Construction moisture</p> <p>OR</p> <p>The building is fully naturally ventilated</p>	1	1	

Continued on next page >>

GREEN BUILDING INDEX ASSESSMENT CRITERIA FOR INDUSTRIAL NEW CONSTRUCTION (INC)

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
OCCUPANT COMFORT				
EQ6	THERMAL COMFORT: DESIGN & CONTROLLABILITY OF SYSTEMS			
	Provide a high level of thermal comfort system control by individual occupant/worker or by specific groups in multi-occupant/worker spaces to promote the productivity, comfort and well-being of occupants and plant workers:			
	Design to ASHRAE 55 in conjunction with the relevant localised parameters as listed in MS1525.	1		
	1) Provide individual comfort control for $\geq 50\%$ of the occupants/workers to enable adjustments to suit individual task needs and preferences., AND 2) Provide comfort system controls for all shared multi-occupant/worker spaces to enable adjustments to suit group needs and preferences. <i>Conditions for thermal comfort include the primary factors of air temperature, radiant temperature, air speed and humidity. Comfort system control for this purpose is defined as the provision of control over at least one of these primary factors in the occupants/workers' local environment.</i>	1	2	
EQ7	AIR CHANGE EFFECTIVENESS			
	Provide effective delivery of clean air through reduced mixing with indoor pollutants in order to promote a healthy indoor environment. Demonstrate that the Air Change Effectiveness (ACE) meets the following criteria for at least 90% of the NLA (air-conditioned areas only): The ventilation systems are designed to achieve an ACE of ≥ 0.95 when measured in accordance with ASHRAE 129: Measuring air change effectiveness where ACE is to be measured in the breathing zone (nominally 1.0m from finished floor level).	1	1	
EQ8	BREAKOUT SPACES			
	Provide breakout space to reduce worker's fatigue for at least 5% of employees per shift.	1	1	
LIGHTING, VISUAL & ACOUSTIC COMFORT				
EQ9	DAYLIGHTING			
	Provide good levels of daylighting for building occupants and plant workers:			
	Demonstrate that $\geq 30\%$ of the NLA has a daylight factor in the range of 1.0 – 3.5% as measured at the working plane, 800mm from floor level, OR	1	2	
	Demonstrate that $\geq 50\%$ of the NLA has a daylight factor in the range of 1.0 – 3.5% as measured at the working plane, 800mm from floor level.	2		
EQ10	DAYLIGHT GLARE CONTROL			
	Reduce discomfort of glare from natural light. Where blinds or screens are fitted on all glazing and atrium as a base building, incorporate provisions to meet the following criteria; 1) Eliminate glare from all direct sun penetration and keep horizontal workspace lux level below 2000; AND 2) Eliminate glare from diffuse sky radiation for occupant workspace at viewing angles of 15° to 60° from the horizontal at eye level (typically 1.2m from floor level); AND 3) Control with an automatic monitoring system (for atrium and windows with incident direct sun light only - not applicable for fixed blinds/screens); AND 4) Equip with a manual override function accessible by occupants (not applicable for fixed blinds/screens)	1	1	
EQ11	ELECTRIC LIGHTING LEVELS			
	Baseline building and plant lighting not to be over designed: Demonstrate that lighting design maintains a luminance level of no more than specified in MS1525 for 90% of NLA (building and industrial plant area) as measured at the working plane (800mm above the floor level).	1	1	
EQ12	HIGH FREQUENCY BALLASTS			
	Increase workplace amenity by avoiding low frequency flicker that may be associated with fluorescent lighting: Install high frequency ballasts in fluorescent luminaires over a minimum of 90% of NLA (building and industrial plant area).	1	1	

Continued on next page >>

GREEN BUILDING INDEX ASSESSMENT CRITERIA FOR INDUSTRIAL NEW CONSTRUCTION (INC)

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
LIGHTING, VISUAL & ACOUSTIC COMFORT (CONTINUED)				
EQ13	EXTERNAL VIEWS			
	Reduce eyestrain for building occupants by allowing long distance views and provision of visual connection to the outdoor. Note that this requirement is applicable to the office building component of the industrial plant only.		2	
	Demonstrate that ≥ 60% of the NLA has a direct line of sight through vision glazing at a height of 1.2m from floor level.	1		
	Demonstrate that ≥ 75% of the NLA has a direct line of sight through vision glazing at a height of 1.2m from floor level.	2		
EQ14	INTERNAL NOISE LEVELS			
	Maintain internal noise levels at an appropriate level. Demonstrate that 90% of the NLA (office component only) do not exceed the following ambient internal noise levels: 1) Within the entire baseline building general office, space noise from the building services does not exceed 40dBAeq, OR 2) Within the baseline building office space, the sound level does not exceed 45dBAeq for open plan and not exceed 40dBAeq for closed offices.	1	1	
VERIFICATION				
EQ15	IAQ BEFORE & DURING OCCUPANCY			
	Reduce indoor air quality problems resulting from the construction process in order to help sustain the comfort and well-being of occupants/workers. Develop and implement an Indoor Air Quality (IAQ) Management Plan for the Pre-Occupancy phase as follows: 1) Perform a building/plant flush out by supplying outdoor air to provide not less than 10 airchanges/hour for at least 30 minutes operation before occupancy and continuous minimum 1 ACH during the initial 14 days occupancy of the completed building/plant, OR 2) If low VOC materials and low formaldehyde composite wood are used, then building/plant flush out can be performed by supplying outdoor air to provide not less than 10 airchanges/hour for at least 15 minutes operation or not less than 6 airchanges/hour for at least 30 minutes operation and continuous 1ACH during the initial 7 days occupancy of the completed building/plant, OR 3) Within 12 months of occupancy, conduct IAQ testing to demonstrate maximum concentrations for pollutants are not exceeded according to the Indoor Air Quality Code of Malaysia.	1	2	
	During Occupancy Stage: Where a permanent air flushing system of at least 10 airchanges/hour operation is installed for use during occupancy stage.	1		
EQ16	POST OCCUPANCY COMFORT SURVEY: VERIFICATION			
	Provide for the assessment of comfort of the building occupants/plant workers: A) Conduct an occupancy comfort survey of occupants/workers annually. This survey should collect anonymous responses about thermal comfort, visual comfort and acoustic comfort in a building/plant. It should include an assessment of overall satisfaction with thermal, visual and acoustic performance and identification of thermal-related, visual-related and acoustic-related problems, AND B) Develop a plan for corrective action if the survey results indicate that more than 20% of occupants/workers are dissatisfied with the overall comfort in the building/plant. This plan should include measurement of relevant environmental variables in problem areas. The relevant environmental variables include 1) Temperature, relative humidity, air speed and mean radiant temperature, 2) Lighting level and glare problem, 3) Background noise level, 4) Odour problem, CO ₂ level, VOCs, and particulate concentration.	1	1	
INDOOR ENVIRONMENTAL QUALITY (EQ) TOTAL			22	

3

SUSTAINABLE SITE PLANNING & MANAGEMENT (SM)

SITE PLANNING | CONSTRUCTION MANAGEMENT | TRANSPORTATION | DESIGN

18 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
SITE PLANNING				
SM1	SITE SELECTION			
	<p>Do not develop building/plant, hardscape, road or parking area on a site or part of a site that meet any one of the following criteria:</p> <ol style="list-style-type: none"> Prime farmland as defined by the Structure Plan of the area or the National Physical Plan. Forest reserve or State Environmental Protection Zones that is specifically identified as habitat for any species found on the endangered lists. Within 30m of any wetlands as defined by the Structure Plan of the area OR within setback distances from wetlands prescribed in state or local regulations, as defined by local or state rule or law, whichever is more stringent. Previously undeveloped land that is within 30m of Mean High Water Spring (MHWS) sea level which supports or could support wildlife or recreational use, or statutory requirements whichever is the more stringent. Previously undeveloped land that is within 20m of lake, river, stream and tributary which support or could support wildlife or recreational use. Land which prior to acquisition for the project was public parkland, unless land of equal or greater value as parkland is provided. 	1	1	
SM2	BROWNFIELD REDEVELOPMENT			
	Reduce pressure on undeveloped land by rehabilitating damaged sites where development is complicated by environmental contamination, thereby reducing pressure on undeveloped land. This would typically involve old rubbish tips, former mining land, old factory sites, etc.	1	1	
SM3	DEVELOPMENT DENSITY & COMMUNITY CONNECTIVITY			
	<p>Channel development to urban area with existing infrastructure, protect greenfield and preserve habitat and natural resources:</p> <p>A) DEVELOPMENT DENSITY Construct building/plant on a previously developed site AND in a community with a minimum density of 20,300m² per hectare net (87,000 sqft per acre net); OR within approved industrial zones</p> <p>B) COMMUNITY CONNECTIVITY Construct a new building/plant or renovate an existing building/plant on a previously developed site AND within 1km of a residential zone or neighbourhood with an average density of 25 units per hectare net (10 units per acre net) AND within 1 km of at least 10 Basic Services AND with pedestrian access between the building/plant and the services.</p> <p>Basic Services include, but are not limited to: 1) Bank; 2) Place of Worship; 3) Convenience/Grocery; 4) Day Care; 5) Police Station; 6) Fire Station; 7) Beauty; 8) Hardware; 9) Laundry; 10) Library; 11) Medical/Dental; 12) Senior Care Facility; 13) Park; 14) Pharmacy; 15) Post Office; 16) Restaurant; 17) School; 18) Supermarket; 19) Theatre; 20) Community Centre; 21) Fitness Centre.</p> <p>Proximity is determined by drawing a 1 km radius around the main building entrance on a site map and counting the services found within that radius.</p>	1	2	
SM4	ENVIRONMENT MANAGEMENT			
	<p>A) Conserve existing natural area and restore damaged area to provide habitat and promote biodiversity & B) Maximize Open Space by providing a high ratio of open space to development footprint to promote biodiversity. Alternatively to adopt existing standard in Industrial Environmental Management.</p> <p>A) Conservation: On previously developed or graded site, restore or protect a minimum of 50% of the site area (excluding the building footprint) with native or adaptive vegetation. Native or adaptive vegetation are plants indigenous to a locality or cultivars of native plants that are adapted to the local climate and are not considered invasive species or noxious weeds. Applicable also to landscaping on rooftops and roof gardens so long as the plants meet the definition of native or adaptive vegetation; OR</p> <p>On greenfield sites, limit all site disturbance to within 12m beyond the building perimeter; 3m beyond surface walkway, patio, surface parking and utilities less than 300mm in diameter; 4.5m beyond primary roadway curb and main utility branch trench; and 7.5m beyond constructed area with permeable surface (such as pervious paving area, storm water detention facility and playing field) that require additional staging area in order to limit compaction in the constructed area.</p> <p>B) Open Space: Reduce by 25%, the development footprint (defined as the total area of the building footprint, hardscape, access road and parking) and/or provide vegetated open space within the project boundary to exceed the local zoning's open space requirement for the site; OR</p> <p>For areas with no local zoning requirement (e.g. university campus, military bases), provide vegetated open space adjacent to the building whose area is equal to that of the building footprint; OR</p> <p>Where a zoning ordinance exists, but there is no requirement for open space (zero), provide vegetated open space equal to 20% of the project's site area.</p>	1	2	
		1		

Continued on next page >>

GREEN BUILDING INDEX ASSESSMENT CRITERIA FOR INDUSTRIAL NEW CONSTRUCTION (INC)

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
SITE PLANNING (CONTINUED)				
SM5	NOISE POLLUTION			
	To encourage and recognise buildings/plants that minimise noise levels diffused from the building/plant outside. Credit point is awarded where the building/plant envelope is designed to reduce noise penetration by at least NR20dBA when in standard operation mode.	1	1	
CONSTRUCTION MANAGEMENT				
SM6	EARTHWORKS - CONSTRUCTION ACTIVITY POLLUTION CONTROL			
	<p>Reduce pollution from construction activities by controlling soil erosion, waterway sedimentation and airborne dust generation.</p> <p>Create and implement an Erosion and Sedimentation Control (ESC) Plan for all construction activities associated with the project. The ESC Plan shall conform to the erosion and sedimentation requirements of the approved Earthworks Plans OR Local erosion and sedimentation control standards and codes, whichever is the more stringent.</p> <p>The plan shall describe the measures implemented to accomplish the following objectives:</p> <ol style="list-style-type: none"> 1. Prevent loss of soil during construction by storm water runoff and/or wind erosion, including protecting topsoil by stockpiling for reuse. 2. Prevent sedimentation of storm sewer or receiving stream. 3. Prevent polluting the air with dust and particulate matter. 	1	1	
SM7	QLASSIC - QUALITY ASSESSMENT SYSTEM FOR BUILDING CONSTRUCTION WORK			
	<p>Achieve quality of workmanship in construction works:</p> <p>Subscribe to independent method to assess and evaluate quality of workmanship of building project based on CIDB's CIS 7: Quality Assessment System for Building Construction Work (QLASSIC). Must achieve a minimum score of 70%.</p>	1	1	
SM8	WORKERS' SITE AMENITIES			
	<p>Reduce pollution from construction activities by controlling pollution from waste and rubbish from workers. Create and implement a Site Amenities Plan for all construction workers associated with the project:</p> <p>The plan shall describe the measures implemented to accomplish the following objectives:</p> <ol style="list-style-type: none"> 1. Proper accommodation for construction workers at the site or at temporary rented accommodation nearby. 2. Prevent pollution of storm sewer or receiving stream by having proper septic tank. 3. Prevent polluting the surrounding area from open burning and proper disposal of domestic waste. 4. Provide adequate health and hygiene facilities for workers on site. 	1	1	
TRANSPORTATION				
SM9	PUBLIC TRANSPORTATION ACCESS & TRANSPORTATION PLAN			
	<p>Reduce pollution and land development impacts from automobile use:</p> <p>Locate project within 1km of an existing, or planned and funded, commuter rail, light rail or subway station.</p> <p>OR</p> <p>Locate project within 500m of at least one bus stop.</p> <p>OR</p> <p>Transportation Plan provided to include provision of Factory Bus service, subsidies for Green Vehicles, Car Pool strategies, Van Pool, pick-up service from train station, etc.</p>	1	1	
SM10	GREEN VEHICLE PRIORITY - LOW EMITTING & FUEL EFFICIENT VEHICLES			
	<p>Encourage use of green vehicles:</p> <p>Provide preferred parking for green vehicles for 5% of the total provided parking spaces.</p> <p>"Preferred parking" refers to the parking spots that are closest to the main entrance of the project (exclusive of spaces designated for handicapped or parking passes provided at a discounted price).</p>	1	1	
SM11	PARKING CAPACITY			
	<p>Discourage over-provision of car parking capacity:</p> <p>Size parking capacity to meet, but not to exceed the minimum local zoning requirements, AND provide preferred parking for carpools or vanpools for 5% of the total provided parking spaces.</p>	1	1	
SM12	CARGO DELIVERY ROUTE AND PROXIMITY			
	<p>Proximity to Major Cargo Transport, e.g. airport, seaport, highway, railway:</p> <p>Credit point is awarded where the building/plant is within 10km of at least 2 major cargo services: Major cargo services are considered to be the following (where they contain cargo facilities):</p> <ul style="list-style-type: none"> • Airport; • Seaport; • Railway Station or Rail Yard; AND <p>Are accessible to Major Freeway entrance/exit (within 5km).</p>	1	1	

Continued on next page >>

GREEN BUILDING INDEX ASSESSMENT CRITERIA FOR INDUSTRIAL NEW CONSTRUCTION (INC)

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
DESIGN				
SM13	STORMWATER DESIGN – QUALITY & QUANTITY CONTROL			
	<p>Limit disruption of natural hydrology by reducing impervious cover, increasing on-site infiltration, and managing storm water runoff. Reduce or eliminate water pollution by reducing impervious cover, increasing onsite infiltration, eliminating sources of contaminants, and removing pollutants from storm water runoff:</p> <p>Condition 1: If existing imperviousness is ≤ 50%: Implement a storm water management plan that prevents the post development peak discharge rate and quantity from exceeding the pre-development peak discharge rate and quantity in conformance to the Storm Water Management Manual for Malaysia (MASMA).</p> <p>Condition 2: If existing imperviousness is > 50%: Implement a storm water management plan that results in a 25% decrease in the volume of storm water runoff required under MASMA.</p> <p>For either Condition, implement a storm water management plan that reduces impervious cover, promotes infiltration, and captures and treats the storm water runoff from 90% of the average annual rainfall using acceptable best management practices (BMPs).</p>	1	1	
SM14	GREENERY & ROOF			
	<p>Reduce heat island (thermal gradient difference between developed and undeveloped areas) to minimise impact on microclimate and human and wildlife habitat:</p> <p>A) Hardscape & Greenery Application: Provide any combination of the following strategies for 50% of the site hardscape (including sidewalks, courtyards, plazas and parking lots):</p> <ol style="list-style-type: none"> 1. Shade (within 5 years of occupancy); 2. Paving materials with a Solar Reflectance Index (SRI) of at least 29; 3. Open grid pavement system; 	1	2	
	<p>B) Roof Application:</p> <ol style="list-style-type: none"> 1. Use roofing material with a Solar Reflectance Index (SRI) equal to or greater than the value in the table below for a minimum of 75% of the roof surface; OR 2. Install a vegetated roof for at least 50% of the roof area; 3. Install high albedo and vegetated roof surfaces that, in combination, meet the following criteria: (Area of SRI Roof / 0.75) + (Area of vegetated roof / 0.5) ≥ Total Roof Area <p>Roof Type Slope SRI Low-Sloped Roof < 2:12 78 Steep-Sloped Roof > 2:12 29</p>	1		
SM15	BUILDING USER MANUAL			
	<p>Document Green building/plant design features and strategies for user information and guide to sustain performance during occupancy:</p> <p>Provide (include updating) a Building User Manual which documents passive and active features that should not be downgraded.</p>	1	1	
SUSTAINABLE SITE PLANNING & MANAGEMENT (SM) TOTAL			18	

4

MATERIALS & RESOURCES (MR)

REUSED & RECYCLED MATERIALS | SUSTAINABLE RESOURCES | WASTE MANAGEMENT | GREEN PRODUCTS

11 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
REUSED & RECYCLED MATERIALS				
MR1	MATERIALS REUSE AND SELECTION			
	Reuse building materials and products to reduce demand for virgin materials and reduce creation of waste. This serves to reduce environmental impact associated with extraction and processing of virgin resources. Integrate building design and its buildability with selection of reused building materials, taking into account their embodied energy, durability, carbon content and life cycle costs:		2	
	Where reused products/materials constitutes $\geq 2\%$ of the project's total material cost value, OR	1		
	Where reused products/materials constitutes $\geq 5\%$ of the project's total material cost value	2		
MR2	RECYCLED CONTENT MATERIALS			
	Increase demand for building products that incorporate recycled content materials in their production: (Recycled content shall be defined in accordance with the International Organization of Standards Document)		2	
	Where use of materials with recycled content is such that the sum of post-consumer recycled plus one-half of the pre-consumer content constitutes $\geq 10\%$ (based on cost) of the total value of the materials in the project, OR	1		
	Where use of materials with recycled content is such that the sum of post-consumer recycled plus one-half of the pre-consumer content constitutes at least 30% (based on cost) of the total value of the materials in the project.	2		
SUSTAINABLE RESOURCES				
MR3	REGIONAL MATERIALS			
	Use building materials and products that are extracted and manufactured within the region, thereby supporting the use of indigenous resources and reducing the environmental impacts resulting from transportation:	1	1	
	Use building materials or products that have been extracted, harvested or recovered, as well as manufactured, within 500km of the project site for $\geq 20\%$ (based on cost) of the total material value. Mechanical, electrical and plumbing components shall not be included. Only include materials permanently installed in the project.			
MR4	SUSTAINABLE TIMBER			
	Encourage environmentally responsible forest management:	1	1	
	Where $\geq 50\%$ of wood-based materials and products used are certified. These components include, but are not limited to, structural framing and general dimensional framing, flooring, sub-flooring, wood doors and finishes. To include wood materials permanently installed and also temporarily purchased for the project. Compliance with Forest Stewardship Council and Malaysian Timber Certification Council requirements.			
WASTE MANAGEMENT				
MR5	STORAGE & COLLECTION OF RECYCLABLES			
	Facilitate reduction of waste generated during construction and during building/plant occupancy that is hauled and disposed of in landfills:	1	1	
	During Construction, provide dedicated area/s and storage for collection of non-hazardous materials for recycling, AND			
	During Building/Plant Occupancy, provide permanent recycle bins and where applicable, dedicated schedule waste area complying with EQA on schedule waste requirement.			
MR6	CONSTRUCTION WASTE MANAGEMENT			
	Develop and implement a construction waste management plan that, as a minimum identifies the materials to be diverted from disposal regardless of whether the materials will be sorted on site or co-mingled. Use Compactor and Baler for waste disposal. Quantify by measuring total truck loads of waste sent for disposal:		2	
	Recycle and/or salvage $\geq 50\%$ volume of non-hazardous construction debris, OR	1		
	Recycle and/or salvage $\geq 75\%$ volume of non-hazardous construction debris.	2		
GREEN PRODUCTS				
MR7	REFRIGERANTS & CLEAN AGENTS			
	Use environmentally-friendly Refrigerants and Clean Agents exceeding Malaysia's commitment to the Montreal & Kyoto protocols:	1	1	
	Use zero Ozone Depleting Potential (ODP) products: non-CFC and non-HCFC refrigerants AND clean agents.			
MATERIALS & RESOURCES (MR) TOTAL			10	

5

WATER EFFICIENCY (WE)

WATER HARVESTING & RECYCLING | INCREASED EFFICIENCY

10 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
WATER HARVESTING & RECYCLING				
WE1	RAINWATER HARVESTING			
	Encourage rainwater harvesting that will lead to reduction in potable water consumption:		2	
	Rainwater harvesting that leads to ≥ 15% reduction in potable water consumption, OR	1		
	Rainwater harvesting that leads to ≥ 30% reduction in potable water consumption.	2		
WE2	WATER RECYCLING			
	Encourage water recycling that will lead to reduction in potable water consumption:		2	
	Treat and recycle ≥ 10% wastewater leading to reduction in potable water consumption, OR	1		
	Treat and recycle ≥ 30% wastewater leading to reduction in potable water consumption.	2		
INCREASED EFFICIENCY				
WE3	WATER EFFICIENT - IRRIGATION/LANDSCAPING			
	Encourage the design of system that does not require the use of potable water supply from the local water authority:		2	
	Reduce potable water consumption for landscape irrigation by ≥ 50% (e.g. through use of native or adaptive plants to reduce or eliminate irrigation requirement), OR	1		
	Not use potable water at all for landscape irrigation.	2		
WE4	WATER REDUCTION			
	Encourage reduction in potable water consumption through use of efficient devices/industrial process:		2	
	Reduce annual potable water consumption by ≥ 30%, OR	1		
	Reduce annual potable water consumption by ≥ 50%	2		
WE5	METERING & LEAK DETECTION SYSTEM			
	Encourage the design of systems that monitors and manages water consumption:		2	
	Use of sub-meters to monitor and manage major water usage for cooling towers, irrigation, kitchens, tenancy use, and industrial process use.	1		
	Link all water sub-meters to EMS to facilitate early detection of water leakage.	1		
WATER EFFICIENCY (WE) TOTAL			10	

6

INNOVATION (IN)

INNOVATION & ENVIRONMENTAL DESIGN INITIATIVES | GBI FACILITATOR

7 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS	MAX POINTS	SCORE
IN1	INNOVATION & ENVIRONMENTAL DESIGN INITIATIVES			
	<p>Provide design team and project the opportunity to be awarded points for exceptional performance above the requirements set by GBI rating system:</p> <p>1 point for each approved innovation and environmental design initiative up to a maximum of 6 points, such as:</p> <ul style="list-style-type: none"> • Condensate water recovery (accounting for at least 50% of total AHUs/FCUs) for use as cooling tower make-up water, etc • Co-generation / Tri-generation system • Thermal / PCM / Thermal Mass storage system (accounting for at least 25% of total required capacity) • Solar thermal technology / Solar Air conditioners (generating at least 10% of total required capacity) • Heat recovery system (contributing to at least 10% of total required capacity) • Heat pipe technology • Light pipes accounting for at least 1% of NLA • Auto-condenser tube cleaning system (fitted to plant equipment serving at least 50% of total capacity) • Non-chemical water treatment system for condenser or chilled water circuit (eg. air and dirt separator, vacuum degasser, etc) • Dynamic balancing control valve system (for entire chilled water system) • Mixed mode / low energy ventilation system • Advanced air filtration technology (serving at least 50% of the GFA) • Waterless urinals (fitted to all male toilets) • Central vacuum system (serving at least 50% of NLA) • Central Pneumatic Waste Collection system • Self-cleaning façade • Electrochromic glazed façade • Refrigerant leakage detection and recycling facilities • Use non-synthetic (natural) Refrigerants AND Clean Agents with zero ODP and negligible Global Warming Potential • ISO 14000 series certification • Recycling of all fire system water during regular testing 	6	6	
IN2	GREEN BUILDING INDEX FACILITATOR			
	<p>To support and encourage the integration required for Green Building Index rated buildings and to streamline the application and certification process:</p> <p>Engage the services of a Green Building Index Facilitator to assist in obtaining Green Building Index certification.</p>	1	1	
INNOVATION (IN) TOTAL			7	