



**GBI ASSESMENT CRITERIA  
NON-RESIDENTIAL EXISTING BUILDING  
(NREB): RETAIL**

VERSION 1.0 | MAY 2013

[www.greenbuildingindex.org](http://www.greenbuildingindex.org) | [info@greenbuildingindex.org](mailto:info@greenbuildingindex.org)

GREENBUILDINGINDEX SDN BHD (845666-V) A-12-13A Menara UOA Bangsar, 5 Jalan Bangsar Utama 1, 59000 Kuala Lumpur, Malaysia  
Tel 603 2694 4182 Fax 603 2697 4182

## CONTENTS

PAGE **2**      **COPYRIGHT AND ACKNOWLEDGEMENTS**

### **INTRODUCTION**

PAGE **3**      What is the Green Building Index (GBI)?

PAGE **3**      Who can use the Green Building Index (Non-Residential)?

PAGE **3**      How to Use the Green Building Index?

PAGE **4**      **PROJECT INFORMATION**

### **ASSESSMENT CRITERIA**

PAGE **5**      Summary of Final Score

PAGE **6**      Summary of Contents

### **INDIVIDUAL ITEM SCORE**

PAGE **8**      **PART 1:** Energy Efficiency (EE)

PAGE **10**     **PART 2:** Indoor Environmental Quality (EQ)

PAGE **13**     **PART 3:** Sustainable Site Planning & Management (SM)

PAGE **14**     **PART 4:** Materials & Resources (MR)

PAGE **15**     **PART 5:** Water Efficiency (WE)

PAGE **16**     **PART 6:** Innovation (IN)

## COPYRIGHT AND ACKNOWLEDGEMENTS

The Green Building Index has been developed by PAM and ACEM for the purposes as mentioned above and may be subject to further updating and/or modification in future.

The Green Building Index (GBI) is based upon the existing rating tools such as the Singapore Green Mark and the Australian Green Star system, amongst others which have been extensively modified for the Malaysian application. Grateful acknowledgment is made to the owners of copyright for these systems for use of their documents, information and materials in the development of the GBI.

While every care has been taken by PAM and ACEM in the development of the GBI to establish and acknowledge copyright of the information and materials used, and contact the copyright owners known to PAM/ACEM, PAM and ACEM tender their apologies for any accidental copyright infringement.

The GBI is a copyright of PAM and ACEM in which PAM and ACEM reserve all rights. No part of the GBI may be used, modified, reproduced, stored in a retrieval system or transmitted in any form, or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written permission of PAM and ACEM.

### DISCLAIMERS

PAM and ACEM shall not be held liable for any improper or incorrect use of the GBI (inclusive of the materials and/or information contained therein) and assume no responsibility for any user's use of it. In no event shall PAM and ACEM be liable for any damages whatsoever, whether direct, indirect, incidental, special, exemplary or consequential (including, but not limited to business interruption or loss of use, data or profits) regardless of cause, and on any basis of liability, whether in contract, strict liability or tort (including negligence, misrepresentation or otherwise) arising in any way out of the use of the GBI or the information and materials contained therein.

The information and materials in the GBI are provided "as is" and without warranties of any kind expressed or implied. PAM and ACEM do not warrant or make representations as to the accuracy and completeness of any information and/or materials contained therein. While every effort has been made to check the accuracy and completeness of the information and materials given, the users should always make their own relevant checks. Accordingly, PAM and ACEM do not accept responsibility and liability for misstatements made in it or misunderstanding from it.

The GBI is no substitute for professional advice. Users are advised to consult with appropriate and accredited professional advisors for advice concerning specific matters pertaining to the GBI before adopting or using it. PAM and ACEM disclaim any responsibility for positions taken by users in their individual cases or for any misunderstandings and losses, direct or indirectly, on the part of the users.

PAM and ACEM do not endorse or otherwise acknowledge the GBI rating achieved by the use of the GBI. PAM and ACEM offer a formal certification process for ratings; which service provides for independent third party review of points claimed to ensure that all credits can be demonstrated to be achieved by the provision of the necessary documentary evidence. Use of the GBI without formal certification by PAM and ACEM does not entitle the user or any other party to promote the achieved GBI rating. Notwithstanding the above, neither the GBI formalization nor any certification issued by PAM and ACEM shall be used for advertising or product/services endorsement purposes.

### INDEMNIFICATION

To the extent permitted by applicable law, by using the GBI, the user agrees to defend, indemnify, and hold harmless, PAM and ACEM, their officers, employees, members, representatives and agents from and against all claims and expenses of whatsoever kind and amount, arising out of the user's use of the GBI or materials and information contained therein and not to pursue any cause of action whatsoever against PAM and ACEM under any conceivable circumstances.

# INTRODUCTION

## WHAT IS THE GREEN BUILDING INDEX (GBI)?

The Green Building Index is an environmental rating system for buildings developed by PAM (Pertubuhan Arkitek Malaysia / Malaysian Institute of Architects) and ACEM (the Association of Consulting Engineers Malaysia). The Green Building Index is Malaysia's first comprehensive rating system for evaluating the environmental design and performance of Malaysian buildings based on the six (6) main criterias of Energy Efficiency, Indoor Environment Quality, Sustainable Site Planning & Management, Materials & Resources, Water Efficiency, and Innovation.

The Green Building Index is fundamentally derived from existing rating tools, including the Singapore Green Mark and the Australian Green Star system, but extensively modified for relevance to the Malaysian tropical weather, environmental context, cultural and social needs.

This PAM/ACEM GBI initiative aims to assist the building industry in its march towards sustainable development. The GBI environmental rating system is created to:

- **Define green building by establishing a common language and standard of measurement;**
- **Promote integrated, whole-building design;**
- **Recognise and reward environmental leadership;**
- **Transform the built environment to reduce the environmental impact of development; and**
- **Ensure new buildings remain relevant in the future and existing buildings are refurbished and thereafter sustained properly to remain relevant.**

## WHO CAN USE THE GREEN BUILDING INDEX (NON-RESIDENTIAL)?

PAM/ACEM encourage all members of Project Teams, Building owners, Developers and other interested parties (including Contractors, Government and Design and Build Contractors) to use the Green Building Index to validate environmental initiatives of the design phase of new non-residential construction or base non-residential building refurbishment; or construction and procurement phase of non-residential buildings. Use of the Green Building Index is encouraged on all such projects to assess and improve their environmental attributes.

Use of the Green Building Index (Non-Residential) tool without formal certification by an independent accredited GBI Certifier does not entitle the user or any other party to promote the Green Building Index rating achieved. No fee is payable to PAM/ACEM for such use, however formal recognition of the Green Building Index rating - and the right to promote same - requires undertaking the formal certification process offered by PAM/ACEM.

Whilst GBI NRNC is a generic rating tool for Office Buildings, the GBI (NREB): RETAIL is a bespoke rating tool for Malls, Shopping Centres & Retail Stores. The GBI (NREB): RETAIL is developed in collaboration with the Malaysia Shopping Malls Association.

*All Green Building Index rating tools are reviewed periodically; please forward any feedback to [info@greenbuildingindex.org](mailto:info@greenbuildingindex.org).*

## HOW TO USE THE GREEN BUILDING INDEX?

- Complete the Building Input worksheet as the building's type and location may affect the predicted rating.
- Complete the remaining worksheets by reviewing each credit in each category and entering the number of points you predict the building will achieve in the 'No. of Points Achieved' column. Calculators are provided for a number of the tool's credits.
- Enter any points that may be achieved but need to be confirmed in the 'Points to be Confirmed' column.
- Enter any comments required in the 'Comments' column.
- The predicted rating is shown in the Summary worksheet. More detail on point scores (both achieved and those to be confirmed) are shown in the Credit Summary and Graphical Summary worksheets at the end of the tool.

# PROJECT INFORMATION

<b>NAME OF BUILDING</b>	
<b>ADDRESS OF BUILDING</b>	
<b>POSTCODE</b>	
<b>STATE</b>	

<b>APPLICANT</b>	
<b>CONTACT PERSON</b>	

<b>ARCHITECT</b>	
<b>CIVIL ENGINEER</b>	
<b>STRUCTURAL ENGINEER</b>	
<b>MECHANICAL ENGINEER</b>	
<b>ELECTRICAL ENGINEER</b>	
<b>QUANTITY SURVEYOR</b>	
<b>LANDSCAPE CONSULTANT</b>	
<b>OTHER SPECIALIST CONSULTANT(S)</b>	1)
	2)
	3)
	4)
	5)
<b>MAIN CONTRACTOR</b>	
<b>LOCAL AUTHORITY</b>	
<b>TOTAL GROSS FLOOR AREA</b>	
<b>LAND AREA FOR LANDED PROPERTY</b>	

<b>BUILDING DESCRIPTION</b>	

## DETAIL ASSESSMENT CRITERIA SUMMARY OF FINAL SCORE

PART	ITEM	MAXIMUM POINTS	SCORE
1	Energy Efficiency	38	0
2	Indoor Environmental Quality	21	0
3	Sustainable Site Planning & Management	10	0
4	Material & Resources	9	0
5	Water Efficiency	12	0
6	Innovation	10	0
<b>TOTAL SCORE</b>		<b>100</b>	<b>0</b>

## GREEN BUILDING INDEX CLASSIFICATION

POINTS	GBI RATING
86 to 100 points	Platinum
76 to 85 points	Gold
66 to 75 points	Silver
50 to 65 points	Certified

# DETAIL ASSESSMENT CRITERIA

## SUMMARY OF CONTENTS

PART	CRITERIA	ITEM	POINTS	TOTAL	
1	<b>EE</b>	<b>ENERGY EFFICIENCY</b>		<b>38</b>	
	<b>Design &amp; Performance</b>				
	EE1	Minimum EE Performance	2		
	EE2	Lighting Zoning	3		
	EE3	Electrical Sub-metering	2		
	EE4	Renewable Energy	5		
	EE5	Advanced or Improved EE Performance - BEI	15		
	<b>Commissioning</b>				
	EE6	Enhanced or Re-commissioning	4		
	EE7	On-going Post Occupancy Commissioning	2		
	<b>Monitoring, Improvement &amp; Maintenance</b>				
EE8	EE Monitoring & Improvement	2			
EE9	Sustainable Maintenance	3			
2	<b>EQ</b>	<b>INDOOR ENVIRONMENTAL QUALITY</b>		<b>21</b>	
	<b>Air Quality</b>				
	EQ1	Minimum IAQ Performance	1		
	EQ2	Environmental Tobacco Smoke (ETS) Control	1		
	EQ3	Carbon Dioxide Monitoring and Control	1		
	EQ4	Indoor Air Pollutants	2		
	EQ5	Mould Prevention	1		
	<b>Thermal Comfort</b>				
	EQ6	Thermal Comfort: Controllability of Systems	2		
	EQ7	Air Change Effectiveness	1		
	<b>Lighting, Visual &amp; Acoustic Comfort</b>				
	EQ8	Daylighting	2		
	EQ9	Daylight Glare Control	1		
	EQ10	Electric Lighting Levels	1		
	EQ11	High Frequency Ballasts	1		
EQ12	External Views	2			
EQ13	Internal Noise Levels	1			
<b>Verification</b>					
EQ14	IAQ Before/During Occupancy	2			
EQ15	Occupancy Comfort Survey: Verification	2			

# DETAIL ASSESSMENT CRITERIA

## SUMMARY OF CONTENTS (CONTINUED)

PART	CRITERIA	ITEM	POINTS	TOTAL
3	<b>SM</b>	<b>SUSTAINABLE SITE PLANNING &amp; MANAGEMENT</b>		<b>10</b>
	<b>Facility Management</b>			
	SM1	GBI Rated Design & Construction	1	
	SM2	Building Exterior Management	1	
	SM3	Integrated Pest Management, Erosion Control & Landscape Mgt	1	
	<b>Transportation</b>			
	SM4	Green Vehicle Priority	1	
	SM5	Parking Capacity	1	
	<b>Reduce Heat Island Effect</b>			
SM6	Greenery & Roof	4		
SM7	Building User Manual	1		
4	<b>MR</b>	<b>MATERIALS &amp; RESOURCES</b>		<b>9</b>
	<b>Reused &amp; Recycled Materials</b>			
	MR1	Material Reuse and Selection	1	
	MR2	Recycle Content Materials	1	
	<b>Sustainable Materials &amp; Resources and Policy</b>			
	MR3	Sustainable Timber	1	
	MR4	Sustainable Purchasing Policy	1	
	<b>Waste Management</b>			
MR5	Storage, Collection & Disposal of recyclables	3		
<b>Green Products</b>				
MR6	Refrigerants & Clean Agents	2		
5	<b>WE</b>	<b>WATER EFFICIENCY</b>		<b>12</b>
	<b>Water Harvesting &amp; Recycling</b>			
	WE1	Rainwater Harvesting	3	
	WE2	Water Recycling	2	
	<b>Increased Efficiency</b>			
	WE3	Water Efficient - Irrigation/Landscaping	2	
	WE4	Water Efficient Fittings	3	
WE5	Metering & Leak Detection System	2		
6	<b>IN</b>	<b>INNOVATION</b>		<b>10</b>
	IN1	Innovation & Environmental Initiatives	9	
	IN2	Green Building Index Facilitator	1	
			<b>TOTAL POINTS</b>	<b>100</b>



1

# ENERGY EFFICIENCY (EE)

DESIGN & PERFORMANCE | COMMISSIONING | MONITORING, IMPROVEMENT & MAINTENANCE

38 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS ALLOCATED	MAX POINTS	SCORE
<b>DESIGN &amp; PERFORMANCE</b>				
<b>EE1</b>	<b>MINIMUM EE PERFORMANCE (MANDATORY COMPLIANCE)</b>			
	Building envelope and installations to achieve minimum energy efficiency (EE) performance so as to reduce energy consumption in buildings, thus reducing CO2 emission to the atmosphere. Building Envelope to meet the following minimum EE requirements as stipulated in MS 1525:		<b>2</b>	
	a. OTTV ≤ 50, RTTV ≤ 25. Submit calculations (use of BEIT software or other GBI approved software is acceptable)	1		
	b. Install Energy Management Control system.	1		
<b>EE2</b>	<b>LIGHTING ZONING</b>			
	Provide flexible lighting controls to optimise energy savings:-		<b>3</b>	
	All individual or enclosed spaces to be individually switched; and the size of individually switched lighting zones shall not exceed 30m <sup>2</sup> for 90% of the NLA; with switching clearly labelled and easily accessible by building occupants.	1		
	Provide auto-sensor controlled lighting in conjunction with daylighting strategy for all perimeter zones and daylight areas, if any	1		
	Provide motion sensors or equivalent to complement lighting zoning for at least 25% of Landlord & Common Areas.	1		
<b>EE3</b>	<b>ELECTRICAL SUB-METERING &amp; TENANT SUB-METERING</b>			
	Monitor energy consumption of key building services as well as all tenancy areas:-		<b>2</b>	
	Provide sub-metering for all energy use ≥ 100kVa	1		
	Provide separate sub-metering for lighting and/or power at each floor or tenancy.	1		
<b>EE4</b>	<b>RENEWABLE ENERGY</b>			
	Encourage use of renewable energy:-		<b>5</b>	
	Where 0.25 % of the Maximum electricity Demand (M.D.) or total electricity consumption, or 2 kWp (PV or equiv) whichever is the greater is generated by renewable energy, <b>OR</b>	1		
	Where 0.5 % of the M.D. or total electricity consumption, or 5 kWp (PV or equiv) whichever is the greater is generated by renewable energy, <b>OR</b>	2		
	Where 1.0 % of the M.D. or total electricity consumption, or 10 kWp (PV or equiv) whichever is the greater is generated by renewable energy, <b>OR</b>	3		
	Where 1.5 % of the M.D. or total electricity consumption, or 20 kWp (PV or equiv) whichever is the greater is generated by renewable energy, <b>OR</b>	4		
	Where 2.0 % of the M.D. or total electricity consumption, or 40 kWp (PV or equiv) whichever is the greater is generated by renewable energy.	5		
<b>EE5</b>	<b>ADVANCED OR IMPROVED EE PERFORMANCE</b>			
	Exceed Energy Efficiency (EE) performance better than the baseline minimum to reduce energy consumption in the building. Achieve Building Energy Intensity (BEI) as defined by GBI for the following corresponding credit points. The default operating hours for Retail/Mall shall be 84 hours per week. Use of BEIT Software (only for Certified & Silver rating) or other GBI approved software/s is acceptable. Non-electricity fuel energy is excluded in the BEI calculation. BEI <sub>1</sub> values listed below apply to Mall consisting of generally retail outlets and other low energy intensity outlets that normally do not operate after hours. BEI <sub>2</sub> values apply to Mall consisting of at least 10% (of its NLA) high energy intensity outlets such as F&B outlets, supermarket, arcade, fitness centre, et cetera; AND outlets operating after hours such as cinema, karaoke, et cetera. Mall with extra high energy intensity use such as Ice skating rink will have BEI values adjusted on a case-to-case basis.		<b>15</b>	
	BEI <sub>1</sub> ≤ 240, BEI <sub>2</sub> ≤ 350, <b>OR</b>	2		
	BEI <sub>1</sub> ≤ 225, BEI <sub>2</sub> ≤ 325, <b>OR</b>	3		
	BEI <sub>1</sub> ≤ 210, BEI <sub>2</sub> ≤ 300, <b>OR</b>	5		
	BEI <sub>1</sub> ≤ 195, BEI <sub>2</sub> ≤ 280, <b>OR</b>	8		
	BEI <sub>1</sub> ≤ 180, BEI <sub>2</sub> ≤ 255, <b>OR</b>	10		
	BEI <sub>1</sub> ≤ 160, BEI <sub>2</sub> ≤ 235, <b>OR</b>	12		
	BEI <sub>1</sub> ≤ 145, BEI <sub>2</sub> ≤ 210	15		

Continued on next page >>

## GREEN BUILDING INDEX ASSESSMENT CRITERIA FOR NREB: RETAIL

ITEM	AREA OF ASSESSMENT	DETAIL POINTS ALLOCATED	MAX POINTS	SCORE
<b>DESIGN &amp; PERFORMANCE</b>				
<b>EE5</b>	<b>ADVANCED EE PERFORMANCE</b>			
	<p><b>OR</b></p> <p>II) Demonstrate Energy savings over the last 3 years from Existing Building historical BEI baseline, to improve by:</p>		<b>15</b>	
	≥ 20% AND with resultant BEI <sub>1</sub> ≤ 320 or BEI <sub>2</sub> ≤ 465	2		
	≥ 25% AND with resultant BEI <sub>1</sub> ≤ 290 or BEI <sub>2</sub> ≤ 420	3		
	≥ 30% AND with resultant BEI <sub>1</sub> ≤ 240 or BEI <sub>2</sub> ≤ 350	5		
	≥ 40% AND with resultant BEI <sub>1</sub> ≤ 225 or BEI <sub>2</sub> ≤ 325	8		
	≥ 50% AND with resultant BEI <sub>1</sub> ≤ 210 or BEI <sub>2</sub> ≤ 300	10		
	≥ 60% AND with resultant BEI <sub>1</sub> ≤ 190 or BEI <sub>2</sub> ≤ 280	12		
	≥ 70% AND with resultant BEI <sub>1</sub> ≤ 175 or BEI <sub>2</sub> ≤ 255	15		
<b>COMMISSIONING</b>				
<b>EE6</b>	<b>ENHANCED COMMISSIONING/RE-COMMISSIONING/RETRO COMMISSIONING OF BUILDING ENERGY SYSTEMS</b>			
	<p>Ensure building's energy related systems are properly commissioned so as to realise their full potential. Appoint a GBI recognised Commissioning Specialist (CxS) to perform the commissioning for all the building's energy related systems in accordance with ASHRAE Commissioning Guideline or other GBI approved equivalent standard by:</p> <p>a) Implement improvements to ensure building's major energy using systems are repaired, operated and maintained effectively to optimize energy performance.</p> <p>b) Develop a commissioning or ongoing commissioning plan for the building's major energy-using systems.</p> <p>c) Provide training for management staff to build awareness and skills in a broad range of sustainable building operations topics, including energy efficiency and building, equipment and systems operations and maintenance.</p> <p>d) Update the building operating plan as necessary to reflect any changes in the occupancy schedule, equipment runtime schedule, design set points and lighting levels.</p>	4	<b>4</b>	
<b>EE7</b>	<b>ON-GOING POST OCCUPANCY COMMISSIONING</b>			
	Carry out up-to-date on-going post occupancy commissioning for all tenancy areas after fit-out changes are completed, if any.		<b>2</b>	
	a) Professional Engineer shall review all tenancy fit-out plans to ensure original design intent is not compromised and sign off the completed works.	1		
	b) CxS shall carry out re-commissioning of the building's energy related systems for the affected tenancy areas.	1		
<b>MONITORING, IMPROVEMENT &amp; MAINTENANCE</b>				
<b>EE8</b>	<b>EE MONITORING &amp; IMPROVEMENT</b>			
	a) Use Energy Management System to monitor and trend log building system performance for HVAC system efficiency including parameters for plant sequencing, etc., <b>AND</b> Monitor sub-metering of building systems to track energy consumption of major building uses and other end use applications e.g. by categorising into building systems or floors.	1	<b>2</b>	
	b) Fully commission and activate Maximum Demand Limiting programme, <b>AND</b> Compile, summarise and submit BEI, Fuel and Water Consumption of the building to GBI on an annual basis during the 3-years validity period or earlier whenever requested by GBI. Submissions shall include monthly energy and water bills.	1		
<b>EE9</b>	<b>SUSTAINABLE MAINTENANCE</b>			
	Ensure the building's energy related systems will continue to perform as intended with proper and sustainable maintenance:-		<b>3</b>	
	a) At least 75% of permanent building maintenance team to participate in the commissioning of all building energy services.	1		
	b) Provide for a designated building maintenance office that is fully equipped with facilities (including tools and instrumentation) and inventory storage,	1		
	c) Provide evidence of documented plan for at least 3-year facility maintenance and preventive maintenance budget (inclusive of staffing and outsourced contracts).	1		
<b>EE SUB-TOTAL</b>		<b>38</b>	<b>38</b>	<b>0</b>

2

## INDOOR ENVIRONMENTAL QUALITY (EQ)

AIR QUALITY | THERMAL COMFORT | LIGHTING, VISUAL & ACOUSTIC COMFORT | VERIFICATION

21 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS ALLOCATED	MAX POINTS	SCORE
<b>AIR QUALITY</b>				
<b>EQ1</b>	<b>MINIMUM IAQ PERFORMANCE</b>			
	Establish minimum indoor air quality (IAQ) performance to enhance indoor air quality in building, thus contributing to the comfort and well-being of the occupants:-		<b>1</b>	
	Meet the minimum requirements of ventilation rate in ASHRAE 62.1:2007 or the local building code whichever is the more stringent.	1		
<b>EQ2</b>	<b>ENVIRONMENTAL TOBACCO SMOKE (ETS) CONTROL</b>			
	Minimize exposure of building occupants, indoor surfaces, and ventilation air distribution systems to Environmental Tobacco Smoke (ETS):-		<b>1</b>	
	a) Prohibit smoking in the building and locate any exterior designated smoking areas away from entries, outdoor air intakes and operable windows <b>OR</b>	1		
	b) Prohibit smoking in the building except in designated smoking rooms and establish negative pressure in the smoking rooms together with provision of effective air filtration system.	1		
<b>EQ3</b>	<b>CARBON DIOXIDE MONITORING AND CONTROL</b>			
	Provide response monitoring of carbon dioxide levels to ensure delivery of minimum outside air requirements:-		<b>1</b>	
	Install carbon dioxide (CO <sub>2</sub> ) monitoring and control system with at least one (1) CO <sub>2</sub> sensor at all main return points on each floor to facilitate continuous monitoring and adjustment of outside air ventilation rates to each floor, and ensure independent control of ventilation rates to maintain CO <sub>2</sub> level ≤ 1,000 ppm.	1		
<b>EQ4</b>	<b>INDOOR AIR POLLUTANTS</b>			
	Reduce detrimental impact on occupant health from finishes that emit internal air pollutants:		<b>2</b>	
	Use low VOC paint and coating throughout the building. Paints and Coatings to comply with requirements specified in international labelling schemes recognized by GBI, <b>AND</b>	1		
	Use low VOC carpet or flooring throughout the building. Carpets to comply with requirements specified in international labelling schemes recognized by GBI. Other types of flooring to comply with requirements under FloorScore developed by Science Certification System or equivalent, <b>AND</b>			
	Use low VOC adhesive and sealant or no adhesive or sealant used.			
	Use products with no added urea formaldehyde. These include: 1) Composite wood and agrifiber products defined as: particleboard, medium density fiberboard (MDF) plywood, wheatboard, strawboard, panel substrates and door cores, <b>AND</b> 2) Laminating adhesives used to fabricate on-site and shop-applied composite wood and agrifiber assemblies, <b>AND</b> 3) Insulation foam, <b>AND</b> 4) Draperies	1		
<b>EQ5</b>	<b>MOULD PREVENTION</b>			
	Design system(s) which reduce the risk of mould growth and its associated detrimental impact on occupant health:  Where it is demonstrated that the mechanical air-conditioned ventilation system will maintain a positive indoor air pressure relative to the exterior and can actively control indoor air humidity to be no more than 70% RH without the use of active control that will consume additional energy.  Ensure that excessive moisture in building is controlled during the retrofit Design, Construction and Operation stages by the consideration and the control of the following:  1) Rainwater leakage through roof and walls 2) Infiltration of moist air 3) Diffusion of moisture through walls, roof and floors 4) Groundwater intrusion into basements and crawl spaces through walls and floors 5) Leaking or burst pipes 6) Indoor moisture sources 7) Construction moisture, <b>OR</b> The building is fully naturally ventilated	1	<b>1</b>	

Continued on next page >>

## GREEN BUILDING INDEX ASSESSMENT CRITERIA FOR NREB: RETAIL

ITEM	AREA OF ASSESSMENT	DETAIL POINTS ALLOCATED	MAX POINTS	SCORE
<b>THERMAL COMFORT</b>				
<b>EQ6</b>	<b>THERMAL COMFORT: CONTROLLABILITY OF SYSTEMS</b>			
	<p>Provide a high level of thermal comfort system control by individual occupants or by specific groups in multi-occupant spaces to promote the productivity, comfort and well-being of building occupants:-</p> <p>Provide individual comfort controls for <math>\geq 50\%</math> of the building occupants to enable adjustments to suit individual task needs and preferences.</p> <p><b>AND</b></p> <p>Provide comfort system controls for all shared multi-occupant spaces to enable adjustments to suit group needs and preferences.</p> <p><i>Conditions for thermal comfort include the primary factors of air temperature, radiant temperature, air speed and humidity. Comfort system control for this purpose is defined as the provision of control over at least one of these primary factors in the occupants' local environment.</i></p>	2	<b>2</b>	
<b>EQ7</b>	<b>AIR CHANGE EFFECTIVENESS</b>			
	<p>Provide effective delivery of clean air through reduced mixing with indoor pollutants in order to promote a healthy indoor environment. Demonstrate that the Air Change Effectiveness (ACE) meets the following criteria for at least 50% of the air-conditioned public areas:</p> <p>The ventilation systems are designed to achieve an ACE of <math>\geq 0.95</math> when measured in accordance with ASHRAE 129-1997: Measuring air change effectiveness where ACE is to be measured in the breathing zone (nominally 1.0 m from finished floor level)</p>	1	<b>1</b>	
<b>LIGHTING, VISUAL &amp; ACOUSTIC COMFORT</b>				
<b>EQ8</b>	<b>DAYLIGHTING</b>			
	<p>Provide good levels of daylighting for building occupants:-</p> <p>Demonstrate that <math>\geq 30\%</math> of the NLA has a daylight factor in the range of 1.0 – 3.5%, <b>OR</b></p> <p>Demonstrate that <math>\geq 50\%</math> of the NLA has a daylight factor in the range of 1.0 – 3.5%.</p> <p>Mall application may consider use of atrium skylighting and/or perimeter wall daylighting. NLA calculation includes retail space, public area and BOH office. For multi-storey (<math>\geq 3</math> Floors) Mall, the required percentage value of NLA is halved.</p>	1 2	<b>2</b>	
<b>EQ9</b>	<b>DAYLIGHT GLARE CONTROL</b>			
	<p>Reduce discomfort of glare from natural light. Where blinds or screens are fitted on all glazing and atrium as a base building, incorporate provisions to meet the following criteria;</p> <p>a) Eliminate glare from all direct sun penetration and keep horizontal workspace lux level below 2000; <b>AND</b></p> <p>b) Eliminate glare from diffuse sky radiation for occupant workspace at viewing angles of <math>15^\circ</math> to <math>60^\circ</math> from the horizontal at eye level (typically 1.2m from floor level); <b>AND</b></p> <p>c) Control with an automatic monitoring system (for atrium and windows with incident direct sun light only - not applicable for fixed blinds/screens); <b>AND</b></p> <p>d) Equip with a manual override function accessible by occupants (not applicable for fixed blinds/screens)</p>	1	<b>1</b>	
<b>EQ10</b>	<b>ELECTRIC LIGHTING LEVELS</b>			
	<p>Baseline building lighting not to be over designed:-</p> <p>Demonstrate that lighting designs for different spaces of the building maintain luminance levels of no more than specified in MS1525 for 90% of NLA.</p>	1	<b>1</b>	
<b>EQ11</b>	<b>HIGH FREQUENCY BALLASTS</b>			
	<p>Increase workplace amenity by avoiding low frequency flicker that may be associated with fluorescent lighting:-</p> <p>Install high frequency ballasts for at least 90% of all fluorescent luminaires used.</p>	1	<b>1</b>	

Continued on next page >>

## GREEN BUILDING INDEX ASSESSMENT CRITERIA FOR NREB: RETAIL

ITEM	AREA OF ASSESSMENT	DETAIL POINTS ALLOCATED	MAX POINTS	SCORE
<b>LIGHTING, VISUAL &amp; ACOUSTIC COMFORT</b>				
<b>EQ12</b>	<b>EXTERNAL VIEWS</b>			
	Reduce eyestrain for building occupants by allowing long distance views and provision of visual connection to the outdoor.		<b>2</b>	
	Innovative design is required, e.g. consider opening up and introducing windows in foodcourts especially to seating areas, and introduce windows to retail units located at the perimeters and ground floor. External views also include views to the sky for atriums.			
	Demonstrate that $\geq 60\%$ of the NLA has a direct line of sight through vision glazing at a height of 1.2m from floor level.	1		
	Demonstrate that $\geq 75\%$ of the NLA has a direct line of sight through vision glazing at a height of 1.2m from floor level.	2		
<b>EQ13</b>	<b>INTERNAL NOISE LEVELS</b>			
	Maintain internal noise levels at an appropriate level. Demonstrate that 90% of the NLA do not exceed the following ambient internal noise levels:-  Within the entire baseline building general office, space noise from the building services does not exceed 40dBAeq. <b>OR</b> Within the baseline building office space, the sound level does not exceed 45dBAeq for open plan and not exceed 40dBAeq for closed offices.  <i>Note that internal noise level thresholds for areas other than office shall not exceed values stipulated in ASHRAE Standard or other GBI approved Standards, Code of Practice or Design Guides; e.g. CIBSE Guide.</i>	1	1	
<b>VERIFICATION</b>				
<b>EQ14</b>	<b>IAQ BEFORE/DURING OCCUPANCY</b>			
	Reduce indoor air quality problems resulting from the construction process (or inherent conditions) in order to improve and sustain the comfort and well-being of building occupants. Develop and implement an Indoor Air Quality (IAQ) Management Plan to effect this requirement as follows:-  a) Perform a building flush out by supplying outdoor air to provide not less than 10 airchanges/hour for at least 30 minutes operation and continuous minimum 1 ACH for the next 14 days. <b>OR</b> b) If low VOC materials and low formaldehyde composite wood are used, then building flush out can be performed by supplying outdoor air to provide not less than 10 airchanges/hour for at least 15 minutes operation or not less than 6 airchanges/hour for at least 30 minutes operation and continuous 1ACH for the next 7 days. <b>OR</b> c) Conduct IAQ testing to demonstrate maximum concentrations for pollutants are not exceeded according to the Indoor Air Quality Code of Malaysia.	1	<b>2</b>	
	<b>Permanent Air Purging System:</b> Where a permanent air flushing system of at least 10 airchanges/hour operation is installed and operated at least once a year during occupancy stage.	1		
<b>EQ15</b>	<b>OCCUPANCY COMFORT SURVEY: VERIFICATION</b>			
	Provide for the assessment of comfort of the building occupants:-  Conduct an occupancy comfort survey of building occupants. This survey should collect anonymous responses about thermal comfort, visual comfort and acoustic comfort in a building. It should include an assessment of overall satisfaction with thermal, visual and acoustic performance and identification of thermal-related, visual-related and acoustic-related problems. <b>AND</b> Develop a plan for corrective action if the survey results indicate that more than 20% of occupants are dissatisfied with the overall comfort in the building. This plan should include measurement of relevant environmental variables in problem areas. The relevant environmental variables include 1) Temperature, relative humidity, air speed and mean radiant temperature, 2) Lighting level and glare problem, 3) Background noise level, 4) Odour problem, CO2 level, VOCs, and particulate concentration.	2	2	
<b>EQ SUB-TOTAL</b>		<b>21</b>	<b>21</b>	<b>0</b>

3

**SUSTAINABLE SITE PLANNING & MANAGEMENT (SM)**

SITE PLANNING | CONSTRUCTION MANAGEMENT | TRANSPORTATION | DESIGN

**10 POINTS**

ITEM	AREA OF ASSESSMENT	DETAIL POINTS ALLOCATED	MAX POINTS	SCORE
<b>FACILITY MANAGEMENT</b>				
<b>SM1</b>	<b>GBI RATED DESIGN &amp; CONSTRUCTION</b>			
	If the building has been previously GBI (or other GBI approved Green Rating system) rated under any category, <b>OR</b> within the last 12 months a comprehensive Energy Efficiency Audit has been conducted.	1	1	
<b>SM2</b>	<b>BUILDING EXTERIOR MANAGEMENT</b>			
	Employ environmentally sensitive building exterior management plan to reduce pollution.		1	
	Use environmentally non-polluting methods and chemicals for cleaning of building exterior including maintenance equipment, chemicals, paint and sealants.	1		
<b>SM3</b>	<b>INTEGRATED PEST MANAGEMENT, EROSION CONTROL &amp; LANDSCAPE MGT</b>			
	Employ environmentally sensitive management to preserve the site's natural components. Minimise harmful chemical use, energy waste, water waste, air pollution, solid waste and/or chemical runoff such as gasoline and oil. The following operational elements must be addressed:		1	
	a) Use of least toxic chemical pesticides, minimum use of chemicals and use only in targeted locations and only for targeted species. Conduct routine inspection and monitoring <b>AND</b> b) Erosion and sedimentation control for ongoing landscape operations including measures that prevent erosion and sedimentation, prevent air pollution from dust or particulate matter and restore eroded areas.	1		
<b>TRANSPORTATION</b>				
<b>SM4</b>	<b>GREEN VEHICLE PRIORITY - LOW EMITTING &amp; FUEL EFFICIENT VEHICLES</b>			
	Encourage use of green vehicles:-		1	
	Provide preferred parking for low-emitting and fuel-efficient vehicles for 5% of the total car parking lots. <i>"Preferred parking" refers to the parking spots that are closest to the main entrance of the project (exclusive of spaces designated for handicapped or parking passes provided at a discounted price).</i>	1		
<b>SM5</b>	<b>PARKING CAPACITY</b>			
	Discourage over-provision of car parking capacity:-		1	
	Size parking capacity not to exceed the minimum local zoning requirements, AND provide preferred parking for carpools or vanpools for 5% of the total provided parking spaces.	1		
<b>REDUCE HEAT ISLAND EFFECT</b>				
<b>SM6</b>	<b>GREENERY &amp; ROOF</b>			
	Reduce heat island (thermal gradient difference between developed and undeveloped areas) to minimize impact on microclimate and human and wildlife habitat:-		4	
	<b>A) Hardscape &amp; Greenery Application:</b> 1) Provide any combination of the following strategies for 50% of the site hardscape (including sidewalks, courtyards, plazas and parking lots): a) Shade (within 5 years of occupancy); b) Paving materials with a Solar Reflectance Index (SRI) of at least 29; c) Open grid pavement system;	2		
	<b>B) Roof Application:</b> 1) Use roofing material with a Solar Reflectance Index (SRI) equal to or greater than the value in the table below for a minimum of 75% of the roof surface; <b>OR</b> 2) Install a vegetated roof for at least 50% of the roof area; 3) Install high albedo and vegetated roof surfaces that, in combination, meet the following criteria: <i>(Area of SRI Roof / 0.75) + (Area of vegetated roof / 0.5) ≥ Total Roof Area</i> <i>Roof Type Slope SRI</i> <i>Low-Sloped Roof &lt; 2:12 78</i> <i>Steep-Sloped Roof &gt; 2:12 29</i>	2		
<b>SM7</b>	<b>BUILDING USER MANUAL</b>			
	Document Green building design features and strategies for user information and guide to sustain performance during occupancy:-		1	
	Provide (include updating) a Building User Manual which documents passive and active features that should not be downgraded.	1		
<b>SM SUB-TOTAL</b>		<b>10</b>	<b>10</b>	<b>0</b>

4

## MATERIALS & RESOURCES (MR)

REUSED & RECYCLED MATERIALS | SUSTAINABLE RESOURCES | WASTE MANAGEMENT | GREEN PRODUCTS

9 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS ALLOCATED	MAX POINTS	SCORE
<b>REUSED AND RECYCLED MATERIALS</b>				
<b>MR1</b>	<b>MATERIALS REUSE AND SELECTION</b>			
	Reuse building materials and products to reduce demand for virgin materials and reduce creation of waste. This serves to reduce environmental impact associated with extraction and processing of virgin resources. Integrate building design and its buildability with selection of reused building materials, taking into account their embodied energy, durability, carbon content and life cycle costs:-		<b>1</b>	
	Where reused products/materials constitutes $\geq 20\%$ of the project's total retrofit material cost value.	1		
<b>MR2</b>	<b>RECYCLED CONTENT MATERIALS</b>			
	Increase demand for building products that incorporate recycled content materials in their production:- <i>(Recycled content shall be defined in accordance with the International Organization of Standards Document)</i>		<b>1</b>	
	Where use of materials with recycled content is such that the sum of post-consumer recycled plus one-half of the pre-consumer content constitutes $\geq 20\%$ (based on cost) of project's total retrofit material cost value.	1		
<b>SUSTAINABLE MATERIALS &amp; RESOURCES AND POLICY</b>				
<b>MR3</b>	<b>SUSTAINABLE TIMBER</b>			
	Encourage environmentally responsible forest management:-		<b>1</b>	
	Where $\geq 75\%$ of wood-based materials and products used in the retrofit works are certified. <i>These components include, but are not limited to, structural framing and general dimensional framing, flooring, sub-flooring, wood doors and finishes. To include wood materials permanently installed and also temporarily purchased for the project. Compliant with Forest Stewardship Council AND Malaysian Timber Certification Council requirements.</i>	1		
<b>MR4</b>	<b>SUSTAINABLE PURCHASING POLICY</b>			
	Develop a Sustainable Purchasing policy that must cover product purchases within the building and management's control.	1	<b>1</b>	
<b>WASTE MANAGEMENT</b>				
<b>MR5</b>	<b>STORAGE, COLLECTION &amp; DISPOSAL OF RECYCLABLES</b>			
	Facilitate reduction of waste generated during retrofit construction and during building occupancy that is hauled and disposed of in landfills:-		<b>3</b>	
	Provide recycling facilities/infrastructure for sorting and separate collection of recyclable waste for recycling (consumables - glass, paper, metal, equipment, addition & alteration construction wastes)	1		
	Promote and encourage waste minimization and recycling among occupants, tenants and visitors through various avenues.	1		
	Promote waste sorting, collecting, quantifying, monitoring and recycling of a large range of waste generated in-house.	1		
<b>GREEN PRODUCTS</b>				
<b>MR6</b>	<b>REFRIGERANTS &amp; CLEAN AGENTS</b>			
	Use environmentally-friendly Refrigerants and Clean Agents exceeding Malaysia's commitment to the Montreal & Kyoto protocols:-		<b>2</b>	
	Use zero Ozone Depleting Potential (ODP) products: non-CFC and non-HCFC refrigerants AND fire suppression clean agents;	1		
	Use non-synthetic (natural) refrigerants AND fire suppression clean agents with zero ODP and negligible Global Warming Potential (GWP $\leq 10$ ).	1		
<b>MR SUB-TOTAL</b>		<b>9</b>	<b>9</b>	<b>0</b>

5

## WATER EFFICIENCY (WE)

WATER HARVESTING & RECYCLING | INCREASED EFFICIENCY

12 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS ALLOCATED	MAX POINTS	SCORE
<b>WATER HARVESTING &amp; RECYCLING</b>				
<b>WE1</b>	<b>RAINWATER HARVESTING</b>			
	Encourage rainwater harvesting that will lead to reduction in potable water consumption:-		<b>3</b>	
	Rainwater harvesting that leads to ≥5% reduction in potable water consumption, <i>OR</i>	1		
	Rainwater harvesting that leads to ≥15% reduction in potable water consumption, <i>OR</i>	2		
	Rainwater harvesting that leads to ≥30% reduction in potable water consumption.	3		
<b>WE2</b>	<b>WATER RECYCLING</b>			
	Encourage water recycling that will lead to reduction in potable water consumption:-		<b>2</b>	
	Treat and recycle ≥10% wastewater leading to reduction in potable water consumption, <i>OR</i>	1		
	Treat and recycle ≥30% wastewater leading to reduction in potable water consumption.	2		
<b>INCREASED EFFICIENCY</b>				
<b>WE3</b>	<b>WATER EFFICIENT - IRRIGATION/LANDSCAPING</b>			
	Reduce potable water consumption for landscape irrigation by:		<b>2</b>	
	a) 50%	1		
	b) 100%	2		
<b>WE4</b>	<b>WATER EFFICIENT FITTINGS</b>			
	Encourage reduction in potable water consumption through use of efficient devices:-		<b>3</b>	
	I) With reference to Utility calculations;			
	a) Reduce annual potable water consumption by ≥20%, <i>OR</i>	1		
	b) Reduce annual potable water consumption by ≥30%, <i>OR</i>	2		
	c) Reduce annual potable water consumption by ≥50%	3		
	<i>OR</i>			
	II) From existing 3-year average water consumption record, reduce annual potable water use by:			
	a) ≥ 20%	1		
	b) ≥ 30%	2		
	c) ≥ 50%	3		
<b>WE5</b>	<b>METERING &amp; LEAK DETECTION SYSTEM</b>			
	Encourage the design of systems that monitors and manages water consumption:-		<b>2</b>	
	Use of sub-meters to monitor and manage major water usage for cooling towers, irrigation, kitchens and tenancy use.	1		
	Link all water sub-meters to EMS to facilitate early detection of water leakage.	1		
<b>WE SUB-TOTAL</b>		<b>12</b>	<b>12</b>	<b>0</b>



6

## INNOVATION (IN)

INNOVATION & ENVIRONMENTAL DESIGN INITIATIVES | GBI FACILITATOR

10 POINTS

ITEM	AREA OF ASSESSMENT	DETAIL POINTS ALLOCATED	MAX POINTS	SCORE
<b>IN1</b>	<b>INNOVATION &amp; ENVIRONMENTAL INITIATIVES</b>			
	<p>Provide Existing Buildings the opportunity to be awarded points for exceptional performance above the requirements set by GBI rating system:-</p> <p>1 point for each approved innovation and environmental initiative up to a maximum of 9 points, such as:-</p> <ul style="list-style-type: none"> <li>• Use of IBS - Industrialized Building System for the retrofit component (must achieve a minimum CIDB IBS score of 30);</li> <li>• Condensate water recovery (accounting for at least 50% of total AHUs/FCUs) for use as cooling tower make-up water etc;</li> <li>• Co-generation / Tri-generation system;</li> <li>• Thermal / PCM / Thermal Mass storage system (accounting for at least 25% of total required capacity);</li> <li>• Solar thermal technology / Solar Thermal Cooling (generating at least 10% of total required capacity);</li> <li>• Heat recovery system (contributing to at least 10% of total required capacity);</li> <li>• Heat pipe technology (for at least 50% of relevant applications);</li> <li>• Light pipes accounting for at least 1% of NLA ;</li> <li>• Auto-condenser tube cleaning system (fitted to plant equipment serving at least 50% of total capacity);</li> <li>• Vacuum degasser cleaning system for chilled water piping system;</li> <li>• Dynamic balancing control valve system (for entire chilled water system);</li> <li>• Non-chemical water treatment system (serving at least 50% of total capacities of plants for HVAC, Boilers, Pools, etc.);</li> <li>• Mixed mode / low energy ventilation system;</li> <li>• Advanced air filtration technology (serving at least 50% of the NLA);</li> <li>• Waterless urinals (fitted to all male toilets);</li> <li>• Central vacuum system (serving at least 50% of NLA);</li> <li>• Central Pneumatic Waste Collection system (serving at least 50% of NLA);</li> <li>• Self-cleaning façade (for at least 10% of façade);</li> <li>• Electrochromic glazed façade (for at least 10% of façade);</li> <li>• Refrigerant leakage detection and recycling facilities (for at least 90% of HVAC plant);</li> <li>• Car park mechanical ventilation fans provided with VSD and controlled by CO<sub>2</sub>/CO sensors.</li> <li>• Recycling of Sprinkler and Wet Riser fire system water during regular testing;</li> </ul>	9	9	
<b>IN2</b>	<b>GREEN BUILDING INDEX FACILITATOR</b>			
	<p>To support and encourage the integration required for Green Building Index rated buildings and to streamline the application and certification process:-</p>		1	
	Engage the services of a Green Building Index Facilitator to assist in obtaining Green Building Index certification.	1		
<b>IN SUB-TOTAL</b>		<b>10</b>	<b>10</b>	<b>0</b>